Daily Diary Report by Bid Item

Contract No.: **04-0120F4**

Diary #: 172 **Const Calendar Day:** 192 **Date: 13-Dec-2012 Thursday**

Inspector Name: **Feather, Bernard** **Title:** **Transportation Engineer**

Inspection Type: Intermittent

Shift Hours: 08:00 am 05:00 pm **Break:** 01:00 **Over Time:**

Federal ID:

Location:

Reviewer: Shedd, Bill **Approved Date:** 20-Nov-14 **Status:** Approved

04-0120F4 **04-SF-80-13.2/13.9** **Self-Anchored** **Suspension Bridge**

Weather

Temperature	**7 AM**	**12 PM**	**4PM**	
Precipitation			**Condition**	Drizzle AM; overcast, PM.

Working Day ☑ If no, explain:

Diary:	Dispute
General Comments	☐
Weekly Safety Meeting, 0800-0900. Misc MEP paperwork. Track Progress of FWS work. No cable caulking was conducted today due to the morning precipitation.	

04-0120F4 **Bid Item: 067** **C-COA-SCW.067** **Seal & Caulk Cable Bands - West of W2**

AMERICAN BRIDGE/FLUOR, A JV

04-0120F4 **Bid Item: 067** **C-COA-SCE.067** **Seal & Caulk Cable Bands - East of W2**

AMERICAN BRIDGE/FLUOR, A JV

04-0120F4 **Bid Item: 125** **0-000-000.125** **DOMESTIC WATER (2 1/2 NPS)**

F.W. SPENCER AND SON, INC

Labor

Trade	Class	Name	RT Hrs	OT Hrs	DT Hrs	Total	Remarks	Dispute
Contractor:	F.W. SPENCER AND SON, INC							
Plumber/Pipefitter	JNM	NARCISO BIAGI	8.00	0.00	0.00	8.00		☐
Plumber/Pipefitter	JNM	DAVID LAW	8.00	0.00	0.00	8.00		☐
Welder	JNM	DAMIAN LLANOS	8.00	0.00	0.00	8.00		☐

Diary:	Dispute
MEP Field Work 125 0-000-000.125	☐
The FWS crew spent the shift finishing welding lugs on the carbon steel pipe at the PS-7 at PP-49. In addition, they readjusted the cabron steel lines along the north barrier of the EB bridge, east of the tower to the expansion loop at PP 81, which had shifted due to load transfer. .	

04-0120F4 **Bid Item: 129** **0-000-000.129** **BOOSTER PUMP STATION**

F.W. SPENCER AND SON, INC